



Underwriters Laboratories Inc.®

P1X
SPRINKLER SYSTEMS

IMO INDUSTRIES INC
BARKSDALE CONTROLS DIV
MR D MCAFEE
3211 FRUITLAND AVE
PO BOX 58843
LOS ANGELES CA 90058

Your most recent listing is shown below. Please review this information and report any inaccuracies to the UL Engineering staff member who handled your Assignment.

VRBR November 18, 1993
Switches, Pressure, For Use in Hazardous Locations

IMO INDUSTRIES INC BARKSDALE CONTROLS DIV , E158638 (N)
LOS ANGELES CA 90058

Class I Groups C and D; Class II, Groups E, F and G.
Series P1X-U, Model P1X followed by B or M, followed by 30, 55, 340 or 800, followed by a blank space or 55, followed by a blank space or P1 thru P10, followed by letter U, followed by Q1 thru Q99 pressure operated switches for sprinkler alarm and sprinkler supervisory service.

3211 FRUITLAND AVE PO BOX 58843

LOOK FOR LISTING MARK ON PRODUCT

939536001

Underwriters Laboratories Inc.®

G11/0243568

212

For information on placing an order for UL Listing Cards in a 3 x 5 inch card format, please refer to the enclosed ordering information.

UNDERWRITERS LABORATORIES INC.

RECEIVED IN

DEC - 6 1993

ENGINEERING

12 Laboratory Drive
P.O. Box 13995

Research Triangle Park,
North Carolina 27709-3995, USA

919/549-1400

Telex: 4937928

FAX No. (919) 549-1842

An independent, not-for-profit organization testing for public safety

333 Pfingsten Road
Northbrook, Illinois 60062-2096, USA
708/272-8800

Telex: 8502543343
FAX No. (708) 272-8129

1285 Walt Whitman Road
Melville, L.I., New York 11747-3081, USA
516/271-8200

Telex: 6852015
FAX No. (516) 271-8259

1655 Scott Blvd.
Santa Clara, California 95050-4169, USA
408/985-2400

Telex: 184219
FAX No. (408) 296-3256